

ROBUS®

RSPMW PLUG IN MICROWAVE SENSOR FOR SONICO PLUS AU Item

RSNMW PLUG IN MICROWAVE SENSOR FOR SONIC5 EU Item


PLEASE READ INSTRUCTION BEFORE COMMENCING INSTALLATION AND RETAIN FOR FUTURE REFERENCES.
! Electrical products can cause death or injury, or damage to property. If in any doubt about the installation or use of this product, consult a competent electrician

Note:


Product technical information and specification may change over time without prior notification. For the latest technical information please visit our web site www.robust.com, www.robust.com.au and www.robustled.co.nz

-25°C < Ta < +50°C, 12-24V DC, Class I, IP65,
 MW Detection radius: 1m-8m,
 Mounting height: Max 12m,
 Factory default setting: 100% sensitivity,
 Hold time 5min,
 Daylight sensor: Sun,
 Dimming level 30%,
 Dimming time:30min

Sensor dimension:



1.




2.

Installation

1. Ensure mains supply is switched off before commencing work.
2. Remove the cover cap at the centre of highbay fitting as per figure a.
3. Screw sensor into the highbay fitting as per figure b.

Sensor coverage



3.



4.

REMOTE CONTROL FOR RSPMW / RSNMW RSNMW-RC

SPECIFICATIONS

Power supply	2 x AAA 1.5V battery, Alkaline preferred
Carrying case	RSNMW-RC in carrying case
Upload range	Up to 15 m (50 ft.)
Op. temperature	0°C ~ 50°C (32°F ~ 122°F)
Dimensions	123 x 70 x 20.3 mm (4. 84" x 2.76" x 0. 8")

LED Group Australia Pty Limited
 Suite B, 2 Pittwin Road
 Capalaba
 Queensland 4157
 Australia
 Tel: 07 3890 5444
 Fax: 07 3890 4777
 Email: purchases@robust.com
 Website: www.robust.com.au

LED Group
 Crowe Hogwarth
 72 Trafalgar Square
 NELSON 7010
 New Zealand
 Tel: +64 3668 5285
 Email: nz_purchases@robust.com
 Website: www.robustled.co.nz

L.E.D Lighting & Electrical Distribution Group Ltd
 IRE: Nangor Road, Dublin 12, D12 E7VP, Ireland
 UK: Bracknell Enterprise & Innovation Hub, Ocean House, 12th Floor, The Ring, Bracknell, Berkshire RG12 1AX, UK
 Tel: +353 1 7099000
 Fax: +353 1 7099060
 Email: info@robust.com
 Website: www.robust.com

Issue 1 300523

WARNING

Remove the batteries if the remote will not be used for more than 30 days

OVERVIEW

The remote control wireless IR Configuration Tool is a handheld tool for remote configuration of IR-enabled fixture integrated sensors. The tool enables device to modify via pushbutton without ladder or tools, and stores up to four sensor parameter modes to speed configuration of multiple sensors. The remote control uses bidirectional IR communication to send and receive sensor settings at mounting height up to 50 feet. The device can display previously established sensor parameters, copy parameters and send new parameters or store parameter profiles. For projects where identical settings may be desired across a large number of areas or spaces, this capability provides a streamlined method of configuration. Settings can be copied throughout a site, or in different sites.

LED INDICATORS

LED	DESCRIPTION	LED	DESCRIPTION
BRIGHTNESS	High end trim turning function (To set the output level of connected lighting during occupancy)		To select the current surrounding Lux value as the daylight threshold. This feature enables the fixture to function well in any real application circumstances
SENSITIVITY	To set the occupancy sensing sensitivity of the Sensor		The daylight sensor stops working, and all motion detected could turn on the lighting fixture, no matter how bright the natural light is
HOLD TIME	The time that the Sensor will turn off (if you choose stand-by level is 0) or dim the light to a low level after the area is vacated	STAND-BY DIM	To set the output level of connected lighting during vacancy. The sensor will regulate the lighting output at the set level. Setting the Stand-by DIM level at 0 means light full off during vacancy
DAYLIGHT SENSOR	To represents various thresholds of natural light level for the Sensor	STAND-BY TIME	To represents the time that the sensor will keep the light at low dim level after the HOLD TIME elapsed

BUTTON OPERATION

Button	DESCRIPTION	Button	DESCRIPTION
	Press the button, the light goes to permanent on or permanent off mode, and the sensor is disabled. (Must press button to quit this mode for setting)		Press button, the sensor starts to function and all settings remain the same as the latest status before the light is switched on/off
	Display the current/lastest setting parameters in LED indicators (The LED indicators will on for showing the setting parameters)		The button is for testing purpose sensitivity only. After you choose sensitivity thresholds, then you press button, the sensor goes to test mode automatically (Hold time is only 2s), meanwhile the stand-by period and daylight sensor are disabled. Press button to quit from this mode
	Press button, all settings go back to setting of DIP witch in sensor		
	Enter in the setting condition, the parameter LEDs of remote control will flash to be selected. And Navigate to Up and Down for choose selected parameter in LED indicators		Navigate to LEFT and RIGHT for choose selected parameters in LED indicators
	Confirm the selected parameters selected parameters in remote control		Open and close smart daylight sensor. Press or enter in the setting condition, the parameter LEDs of remote control will flash to be selected, Press for open or close smart daylight sensor
	Press button, upload the current parameters to sensor, the LED light which the sensor connects will on/off as confirm		
	4 Scene modes with preset parameters which are available to be changes and saved in modes		

SETTING

The Setting Content contains all available settings and parameters for remote sensors. It allows you to change the available control, parameters and operation of the sensor from factory default or current parameters.

Change multiple settings of sensor(s)

- Press **(DISP)** button, the remote control leds will show the latest parameters you set.
Note: If you push **(ON/OFF)** button before, you must push **(AUTO)** button to unlock the sensor.
- Press **(▲)** or **(▼)** enter in the setting condition, the parameter leds of remote control will flash to be selected, navigate to the desired setting by pressing **(▲)** **(▼)** **(◀)** **(▶)** to select the new parameters.
- Press OK to confirm all setting and saving.
- Aim at the target sensor and press **(SEND)** to upload the new parameter, the LED light which the sensor connects will on/off as confirm.
Note: The setting works key step is by Push **(▲)** or **(▼)**, enter in the setting condition.
Note: The LED light which the sensor connects will on/off after getting the new parameter as confirm.
Note: If you press **(DISP)** button, the remote LED indicators will show the latest parameters which were sent.

Change multiple settings of sensor(s) with smart photocell sensor open


- Press **(DISP)**, the remote LED indicators will show the latest parameters.
- Press **(▲)** or **(▼)** enter in the setting condition, the parameter LED indicators of remote control will flash to be selected.
- Press **(F)**, 2 LED indicators will flash in daylight sensor settings, select daylight **(10)** **(30)** **(50)** as setpoint to light on automatically, select daylight **(100)** **(300)** **(500)** as setpoint to light off automatically.
- Press OK to confirm all setting and saving.
- Aim at the target sensor and press **(SEND)** to upload the new parameter. The LED light which the sensor connects will on/off.

Note: **(F)** is disabled by default.

- Open or close the smart daylight sensor by push **(F)** when remote control is in setting condition.
- When the smart daylight sensor open, 2 LED indicators are flash in daylight sensor setting. Select daylight **(10)** **(30)** **(50)** as setpoint to light on automatically, select daylight **(100)** **(300)** **(500)** as setpoint to light off automatically. When smart daylight sensor close, 1 LED indicator is flash in the daylight sensor setting for choose daylight sensor threshold.
- When the smart daylight sensor open, the stand-by time is only **(+∞)**.
- Smart daylight sensor takes place of normal photocell sensor and works independently.
- See Daylight Sensor Function.

Corridor Function

This function inside the motion sensor to achieve tri-level control, for some areas which require a light change notice before switch-off. The sensor offers 3 levels of light: 100%-->dimmed light (natural light is insufficient) -->off; and 2 periods of selectable waiting time: motion hold-time and stand-by period; Selectable daylight threshold and freedom of detection area.



With sufficient natural light, the light does not switch on when presence is detected.

With insufficient natural light, the sensor switches on the light automatically when presence is detected.

After hold-time, the light dims to stand-by level if the surrounding natural light is below the daylight threshold.

Light switches off automatically after the stand-by period elapses.

Daylight Sensor Function


Open the daylight sensor by push **(F)** when remote control is in setting condition.




The light switches on at 100% when presence is detected.

The light dims to stand-by level after the hold-time.


The light remains in dimming level at night.



100% on when presence is detected, and dims to 10% in long time absence




When the natural light level exceeds setpoint Lux in the sensor, the light will turn off even if when the space is occupied.



The light automatically turns on at 10% when natural light is insufficient (no motion).

Settings on this demonstration:
Hold-time: 30min
Setpoint to light on: 50lux
Setpoint to light off: 300lux
Stand-by Dim: 10%
Stand-by period: +∞
(when the smart photocell sensor open, the stand-by time is only +∞)



Corridor Function VS Daylight Sensor Function.

- In corridor function, turn on the light MUST by natural light level lower daylight sensor setting and Occupancy. In smart daylight sensor function, turn on the light by natural light level lower daylight setpoint to light on even if vacancy.
- In corridor function, turn off light by stand-by time finish if vacancy. In smart daylight sensor function, turn off the light by natural light level higher than daylight setpoint to light off even if occupancy.
- In smart daylight sensor function, natural light level lighter/lower than daylight setpoint to light off/on MUST keep at least 1mintue, that will turn off/on the light automatically.

About RESET and MODE(1,2,3,4)

The remote control comes with 4 Scene MODES which are not default. You may make desired parameters and save as the new MODE(1,2,3,4) to configure the installed sensors.

RESET: all settings go back to settings of DIPSwitch in sensor

SCENE MODES(1 2 3 4)

MODE	BRIGHTNESS	SENSITIVITY	HOLD TIME	DAYLIGHT SENSOR	STAND-BY DIM	STAND-BY TIME
MODE1	70%	20%	10s	☀️	0%	+∞
MODE 2	70%	20%	10s	☀️	0%	+∞
MODE 3	70%	20%	10s	☀️	0%	+∞
MODE 4	70%	20%	10s	☀️	0%	+∞

Change the MODES:

- press **(MODE1)** / **(MODE2)** / **(MODE3)** / **(MODE4)** button, the remote control Led indicators show existing parameters.
- press **(▲)** **(▼)** **(◀)** **(▶)** to select the new parameters.
- Press OK to confirm all parameters and saving in the mode.

UPLOAD

The upload function allows you to configure the sensor with all parameters in one operation. You may select **CURRENT SETTING** parameters or the **MODE** for uploading. Current setting parameters or the **MODE** are displayed in Remote control.

Upload the current parameters to sensor(s), and duplicate the sensor parameters form one to another

- Press **(DISP)** button or press **(MODE1)** / **(MODE2)** / **(MODE3)** / **(MODE4)**, all parameters are displayed in Remote control.
Note: check if all parameters are correct, if not, change them.
- Aim at the sensor and press **(SEND)** button, the light that sensor connects will be on/of SEND f as confirm.
Note: if other sensor need same parameters, just aim at the sensor and press **(SEND)** button.