

CERTNUMBER: 160524



Address:

Elektroskandia Baltics OÜ

Order Ref: 000485

Valukoja 5

11415 Tallinn, Estonia

CERTIFICATE **of conformity**

#	DESCRIPTION	QT	Application
1	LIYCY-JZ	500 M	<p>Used as junction or connecting cables in control, measuring and signaling technology as well as in data processing and office technology. Suitable for fixed installation or flexible applications with unrestricted mobility without forced movement control and without exposure to tensile load. Installation in dry and moist rooms; outdoor installation not permitted. The tight copper screening provides optimum protection against external electrical interference.</p> <p>Construction</p> <ul style="list-style-type: none">- fine strands of bare copper wire- stranding acc. to VDE 0295 class 5- cores twisted into layers- Green-yellow protective conductor- foil wrapping- PVC core insulation- black cores with printed consecutive number coding- overall braiding of tinned copper wires- PVC outer sheath grey, RAL 7001 <p>Cable are produced according to the datasheet on the website:</p> <p>http://www.kabeltec.de/index.php/de/</p>

Our Quality Control is Approved DIN EN ISO 9001 : 1994

NAME: Jenny Martin

DATE: 24 May 2016

For and on behalf of Kabeltec GmbH



Kabeltec GmbH
Werkstraße 43
78727 Oberndorf a.N
Tel.: 0 74 23 / 921 - 0